

QuickStart Fire Alarm Control Panel Operating Instructions

RESPONDING TO ALARM SIGNALS

1. Evacuate the area.
2. Notify the proper authorities immediately and state the nature and location of the emergency.
3. Be prepared to provide directions to firefighters.

WARNING: Do not silence alarm notification signals until after all occupants have been evacuated.

To silence alarm notification signals:

1. Turn the Enable Controls key switch to the ON position then press Alarm Silence.

– or –

Press Alarm Silence then enter the required password.

Pressing Alarm Silence turns on the Alarm Silence LED and turns off all audible notification appliances. Visible notification appliances may turn off, if configured to do so. A new alarm event or pressing Alarm Silence again cancels the operation and turns the notification appliances on.

Note: Depending on panel programming, notification appliances may not silence if water is flowing through the sprinkler system, and Alarm Silence may be inhibited for up to 5 minutes after the panel goes into alarm.

To view which devices in a zone signaled an alarm:

1. Use the up and down cursor switches to select the zone's event message on the alphanumeric display then press Help.

To return the system to normal after an alarm:

1. Make sure all smoke detectors are free of smoke and all manual pull stations are restored to normal.
2. Turn the Enable Controls key switch to the ON position then press Reset.

– or –

Press Reset then enter the required password.

The Reset LED flashes at different intervals while the system is resetting then turns off.

Note: Depending on panel programming, Reset may be inhibited for up to 5 minutes after the panel goes into alarm.

SOUNDING AN ALARM

1. Turn the Enable Controls key switch to the ON position, press Drill, then press Enter to confirm.

– or –

Press Drill, press Enter to confirm, and then enter the required password.

Pressing Drill turns on the Drill LED and all audible notification appliances. Visible notification appliances may turn on, if configured to do so. Pressing Drill again or pressing Alarm Silence cancels the operation and turns the notification appliances off. Sounding an alarm does not automatically notify the Fire Department.

RESPONDING TO TROUBLE SIGNALS

WARNING: Trouble conditions may affect the panel's ability to provide early detection and indication of a fire. Notify authorized service personnel immediately and clear all trouble conditions as soon as possible.

To silence the panel trouble buzzer:

1. Turn the Enable Controls key switch to the ON position then press Panel Silence.

– or –

Press Panel Silence then enter the required password.

Pressing Panel Silence turns off the panel buzzer and turns on the Panel Silence/Acknowledge LED. Any new event introduced to the panel turns the panel buzzer back on.

Note: Depending on panel programming, unresolved system troubles will cause the panel buzzer to re-sound within 24 hours after being silenced.

PERFORMING A LAMP TEST

1. Press Menu, choose Test, and then Lamp Test.

Installed by:

Name: _____

Company: _____

Address: _____

Phone: _____

Per NFPA 72:

- Protected Premises Fire Alarm System, Local
- Auxiliary Fire Alarm System
- Remote Supervising Station Fire Alarm System
- Central Station Fire Alarm System
- Releasing per NFPA 11, 11A, 12, 13, 15, 16, and 17

Date: _____

For service contact:

Company: _____

Address: _____

Phone: _____

Acceptance Inspection by:

Date: _____

For additional information, refer to the following manuals: QS4 Technical Reference P/N 3100186, QSC Technical Reference P/N 3100185, or QS1 Technical Reference P/N 3100184.